



**BUREAU
VERITAS**

Certificate of compliance

Applicant: **Steca Elektronik GmbH**
Mammostraße 1
87700 Memmingen
Germany

Product: **Automatic disconnection device between a generator and the public low-voltage grid**

Model:

| | |
|-----------------------|------------------------|
| StecaGrid 4200 | StecaGrid 4200x |
| StecaGrid 3600 | StecaGrid 3600x |
| StecaGrid 3010 | StecaGrid 3010x |
| StecaGrid 3000 | |
| StecaGrid 2500 | StecaGrid 2500x |
| StecaGrid 2300 | StecaGrid 2300x |
| StecaGrid 2000 | StecaGrid 2000x |
| StecaGrid 1800 | StecaGrid 1800x |
| StecaGrid 1500 | StecaGrid 1500x |

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with DIN V VDE V 0126-1-1:2006-02 and DIN V VDE V 0126-1-1/A1:2012-02 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function which the distribution network provider can access at any time.

Applied rules and standards:

DIN V VDE V 0126-1-1 (VDE V 0126-1-1):2006-02

Automatic disconnection device between a generator and the public low-voltage grid

DIN V VDE V 0126-1-1/A1 (VDE V 0126-1-1/A1):2012-02

Automatic disconnection device between a generator and the public low-voltage grid; Amendment 1.

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report number: **10TH0241-VDE0126**
Certificate number: **U15-0324**
Date of issue: **2015-08-19**

Certification body

Dieter Zitzmann



Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to EN 45011 - ISO / IEC Guide 65