

Certificate of compliance

Applicant:	Steca Elektronik GmbH
	Mammostr. 1
	87700 Memmingen
	Germany
Product:	Grid-tied photovoltaic inverter
Model:	StecaGrid 4200, StecaGrid 4200x, StecaGrid 3600,
	StecaGrid 3600x, StecaGrid 3010, StecaGrid 3010x,
	StecaGrid 3000, StecaGrid 2500, StecaGrid 2500x,
	StecaGrid 2300, StecaGrid 2300x, StecaGrid 2000,
	StecaGrid 2000x, StecaGrid 1800, StecaGrid 1800x,
	StecaGrid 1500, StecaGrid 1500x

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with IEC 61727:2004 and IEC 62116:2008 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards:

IEC 61727:2004

Photovoltaic (PV) systems - Characteristics of the utility interface

IEC 62116:2008

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters **IEC 62109-1:2010**

Safety of power converters for use in photovoltaic power systems - Part 1: General requirements IEC 62109-2:2011

Safety of power converters for use in photovoltaic power systems - Part 2: Particular requirements for inverters

The following values according IEC61727 and IEC62116 were applied:

under voltage limit (level 1):	195,5V
under voltage limit (level 2):	115,0V
over voltage limit (level 1):	253,0V
overvoltage limit (level 2):	310,0V
At the time of incurs	af 11-1-

lower frequency limit:	49,0Hz
upper frequency limit:	51,0Hz
loss of main detection limit:	2s

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number:

10TH0241-IEC61727 10TH0241-IEC62116 10TH0241-IEC62109-1 10TH0241-IEC62109-2

Certificate number: Date of issue:

2015-08-19

U15-0336

Certification body



Dieter Zitzmann

Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to EN 45011 - ISO / IEC Guide 65

BUREAU VERITAS Consumer Products Services Germany GmbH Businesspark A96, 86842 Türkheim, Germany Phone: + 49 40 74041-0 cps-tuerkheim@de.bureauveritas.com www.bureauveritas.de/cps