

Certificate

Applicant: **Steca Elektronik GmbH**
Mammostraße 1
87700 Memmingen
Germany

Product: **PV Inverter with integrated utility interface**

Model: **StecaGrid 1511, StecaGrid 2011, StecaGrid 2511,
StecaGrid 3011, StecaGrid 3011_2,
StecaGrid 3611, StecaGrid 3611_2,
StecaGrid 4611_2**

Intended use:

Automatic disconnection device with single-phase mains surveillance in accordance with IEC 62116 for photovoltaic systems with single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

SOP-9-1_11 GCC Certification Program, 04/18

Based on:

IEC 62116:2014

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 17PP299-04

Certificate No: 18-178-01

Date of issue: 2018-08-29



Tanja Rottach
Certification

